



# Greensburg Water Works Consumer Confidence Report 2010

**Quality  
On Tap!**  
Our Commitment  Our Profession



**Rick Denney**  
Superintendent  
1105 N. Ireland St.  
Greensburg, IN 47240

812-663-2641  
812-663-2346  
Fax: 812-662-0620  
E-mail: [watersupt@cityofgreensburg.com](mailto:watersupt@cityofgreensburg.com)

**2010**  
***Annual Drinking Water Quality Report***  
Greensburg. Municipal Water Works

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water comes from two sources: Surface water from Flatrock River which is located 6 miles Northwest of Greensburg on Highway 421 and; Ground water from six (6) wells which are located in an aquifer that runs along Freeland Road and North Ireland Street. Well information is available through our Wellhead Protection Program.

I'm pleased to report that our drinking water is safe and meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Rick Denney (voice 812.663.2641, 812.663.2346 - fax 812.662.0620) E-mail: watersupt@cityofgreensburg.com. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3<sup>rd</sup> Tuesday of every month at 6:00 p.m. at City Hall, located at 314 W. Washington Street.

The Greensburg Municipal Water Works routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2010. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Nephelometric Turbidity unit (NTU)* - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of disinfectant allowed in drinking water.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health.

## TEST RESULTS

Contaminant	Range	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
01. Turbidity	.10 to .28	.15 Yearly Average	NTU	n/a	TT = 0.5	Soil runoff
Highest single measurement = .28 all of our samples were below the turbidity limits specified for our filtration technology. Turbidity is measured to determine the clarity of the water after filtration. It is used to determine whether small particles that could cause disease are able to get through our treatment process and into the water system.						
02. Total ColiForm	2 Positives					2 Positive Samples with repeats being negative
<b>Inorganic Contaminants</b>						
03. Copper		*90% value 0.2677	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
04. Fluoride	0.2 to 1.4	0.9 yearly ave.	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
05. Nitrate (as Nitrogen)	1 Test	0.584	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
06. Lead	6.6	0.0072	ppb	0.015	AL=15	
<p>"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CCR is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>".</p> <p>Nitrates: As a precaution we always notify physicians and health care providers in this area if there is ever a higher than normal level of nitrates in the water supply.</p> <p>*Copper: 90% of samples at or below this level. (30 samples taken in 2008.)</p>						
<b>Disinfection By-products &amp; Precursors</b>						
07. TTHM [Total trihalomethanes]	24.3 to 76.2	AVG. 52.9	ppb	N/A	80	By-product of drinking water chlorination
08. HAA5's Total	17.1 to 59.9	AVG. 39.8	ppb	N/A	60	By-product of drinking water chlorination
09. Total Organic Carbon	1.06 to 2.36	AVG. 1.7	ppm	N/A	>1.0 Annual Avg.	By product of drinking water chlorination
<b>Unregulated Contaminates</b>						
10. Sodium	1 test	10.72	ppm	None	None	Consumer Information
11. Water Hardness		320 =19 grains	gpg			Moderately Soft-Consumer Information
12. Gross Alpha		3.3pci/l		W/A		
13. Gross Beta		0.7 mrem/yr		N/A		
<b>Volatile Organic Contaminants</b>						
14. Bromodichloromethane		5.5	ug/l	N/A	N/A	
15. Chloroform		26.6	ug/l	N/A	N/A	
16. Chlorodibromomethane		0.6	ug/l	N/A	N/A	

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or are man made. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials.


The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- Organic chemicals, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive materials, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food & Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at Greensburg Municipal Water Works work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



Greensburg Water Works  
1105 N. Ireland St.  
Greensburg, IN 47240  
(812) 663-2641

PRESORTED  
PRSR STD  
U.S. Postage  
PAID  
PERMIT No.80